

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No.....323

Date. 02/09/2023

It is certified that SUNBEAM CENTRAL SCHOOL, KOSUK, BIHARSHARIF, NALANDA has good drinking water Facility for the student and staffs of the institution and it is maintaining the hygienic sanitation condition in the school building & the Campus.

Enclosure: Certificate from Water

Testing Laboratory Biharshaif

Signature with Seal :-

Name :-

Designation :-

Name & Address of the Office/Department :-

02/09/2023
 लोक स्वास्थ्य अवर प्रमाण
 सागर सिंह
 SDO, PH SUBDIVISION,
 BIHARSHARIF
 PH DIVISION, BIHARSHARIF

To,

SUNBEAM CENTRAL SCHOOL,
 KOSUK, BIHARSHARIF, NALANDA
 (Name & address of the Institution)

**Government of Bihar
Public Health Engineering Department**

Water Quality Report

District Name: Nalanda Division Name: Public Health Engineering Division, Biharsharif Format: I
 Sample Collected by: - Ravindra Kumar, Staff Sunbeam Central School, Kosuk Date of Sampling: - 06/05/2023

Sl. No.	Block	Nagar Nigam	Village	Name of Habitation	Ward No.	Location of Source	Test result													Source of Water			
							pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F		T.Coli		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22		
1	Biharsharif	Nagar Nigam Biharsharif	Kosuk	Kosuk	50	Sunbeam Central School, Kosuk	8.32	0.45	610	400	220	48	17	50	240	0.15	0.28	7.5	1	<1.1		Tube Well	
							Desirable Limit*	1.0	500	200	75	30	250	200	0.3	45	200	1.0	-	-	-		
							Permissible Limit* in absence of alternate source	NR	5.0	2000	600	200	100	1000	600	1.0	NR	400	1.5	-	-	-	

Remarks: - Analysed sample water is satisfactory for drinking & domestic Purpose

Rajesh Kumar
12/05/2023

Chemist
Public Health Division, Biharsharif
(Nalanda)
Chemist
Public Health Division
Bihar Sharif (Nalanda)